



Certificate of constancy of performance for smoke alarm device

In compliance with the Regulation 305/2011/UE of the European Parliament and of the Council of 9 March 2011 (Construction Products Regulation or CPR)

Delivered by:

Certification body: AFNOR Certification
Identification number: 0333
Address: 11, rue Francis de Pressensé
FR-93571 La Plaine Saint-Denis Cedex

Issued to:

Manufacturer: NETATMO
Address: 73/77 rue de Sèvres 92100 Boulogne Billancourt France

Manufacturing site: CELESTICA Bihor ROUMANIE

Description of the product: see Annex

AFNOR Certification attests that the provisions concerning the assessment and verification of constancy of performance and the performances described in annex ZA of the standard EN 14604 : 2005 + AC : 2008 under system 1 and that smoke alarm device fulfills the provisions described in annex ZA of the standard EN 14604 : 2005 + AC : 2008.

Certificate number: 0333-CPR-292168

Conditions and certificate validity period: this certificate was first issued on 9/14/2018.

Unless suspended or withdrawn, this certificate remains valid as long as the conditions laid down in the harmonized technical specifications or the manufacturing conditions in the factory or the factory production control itself are not significantly modified.

This certificate cancels and replaces any previous certificate

Date of issue of the certificate: 1/28/2022

Certificate expiry date : 1/10/2025



Julien NIZRI
Managing Director of AFNOR Certification

Annex to the certificate issued on 1/28/2022: 0333-CPR-292168

Manufacturer: **NETATMO**
Address: **73/77 rue de Sèvres 92100 Boulogne Billancourt France**

Manufacturing site: **CELESTICA Bihor ROUMANIE**

Product description:

| | |
|--|--------------------------|
| Commercial reference | NSD01 |
| Trade mark | NETATMO |
| Type of mounting | Wall or Ceiling |
| Main power supply | Internal power source |
| Battery name | CR17450E-R (FDK) |
| Battery duration | 10 years |
| Connection of external ancillary devices | No |
| Individual alarm indicator | Yes |
| Interconnectable device | No |
| Suitable for installation in recreational vehicles | Yes |
| Alarm silence facility | Yes |
| File number | 292.202109 292.202118 |

This annex cannot be submitted or reproduced without the document to which it is attached.



Julien NIZRI
Managing Director of AFNOR Certification