



Certificate of constancy of performance for smoke alarm device

In compliance with the Regulation 305/2011/UE of the European Parliament and of the Council of 9 March 2011 (Construction Products Regulation or CPR)

Delivered by:

Certification body: AFNOR Certification
Identification number: 0333
Address: 11, rue Francis de Pressensé
FR-93571 La Plaine Saint-Denis Cedex

Issued to:

Manufacturer: NETATMO
Address: 73/77 rue de Sèvres 92100 Boulogne Billancourt France

Manufacturing site: GLD VILLARD BONNOT France
CELESTICA Bihor ROUMANIE

Description of the product: see Annex

AFNOR Certification attests that the provisions concerning the assessment and verification of constancy of performance and the performances described in annex ZA of the standard EN 14604 : 2005 + AC : 2008 under system 1 and that smoke alarm device fulfills the provisions described in annex ZA of the standard EN 14604 : 2005 + AC : 2008.

Certificate number: 0333-CPR-292168

Conditions and certificate validity period: this certificate was first issued on 9/14/2018.

Unless suspended or withdrawn, this certificate remains valid as long as the conditions laid down in the harmonized technical specifications or the manufacturing conditions in the factory or the factory production control itself are not significantly modified.

This certificate cancels and replaces any previous certificate

Date of issue of the certificate: 5/20/2021

Certificate expiry date : 1/10/2025



Julien NIZRI
Managing Director of AFNOR Certification



Annex to the certificate issued on 5/20/2021: 0333-CPR-292168

Manufacturer **NETATMO**
Address: **73/77 rue de Sèvres 92100 Boulogne Billancourt France**

Manufacturing site: **GLD VILLARD BONNOT France**
CELESTICA Bihor ROUMANIE

Product description:

Commercial reference	NSD01
Trade mark	NETATMO
Type of mounting	Wall or ceiling
Main power supply	Internal power source
Battery name	CR17450E-R (FDK)
Battery duration	10 years
Connection of external ancillary devices	No
Individual alarm indicator	Yes
Interconnectable device	No
Suitable for installation in recreational vehicles	Yes
Alarm silence facility	Yes
File number	292.0672 292.0698

This annex cannot be submitted or reproduced without the document to which it is attached.